

Copy of the certificate regarding Water, Health & Sanitation issued by Dy.
MOH, Surat Municipal Corporation

Dr. RIKITA J. PATEL
DY. M.O.H.
MBBS, MD. (Community
Medicine)
WEST ZONE (RANDER)



WEST ZONE (RANDER)
SURAT MUNICIPAL
CORPORATION, TADWADI,
RANDER ROAD, SURAT
PHONE (0) 2786181-82-83

Outward No. 2302
Date :- 21/06/25
West Zone

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an Inspection Team Headed by Dr. Rikita J. Patel , Dy.
MOH from Health Department, West Zone (Rander) inspected the K7 International
High School, TP 8, FP. 1 Nr. BRTS Bus Charging Station, Canal Road,
Palapurgam, Surat on Dt.24/04/2025 and found that the K7 International High School
has safe drinking water facilities for the students and members of staff of the institution
and is maintaining the hygienic sanitation condition in the school building & the campus
as per norms prescribed by the Central/State/ U.T Govt.

The above certificate is valid for a period of 1 Year.



Rikita
DY. MOH
WEST ZONE
SURAT MUNICIPAL CORPORATION

TO
K7 International High School,
TP 8, FP. 1 Nr. BRTS Bus Charging Station,
Canal Road,
Palapurgam,
Surat

Gimbalkar

Principal-I/C

K7 International High School, Surat.

K7 International High School

Chaudhary

Trustee

Copy of the Water Examination Report



Public Health Laboratory

Surat Municipal Corporation
2nd Floor, Vesu Urban Community Health Center
Opp. Vesu Fire Station, VIP Road,
Vesu, Surat - 395007 Gujarat

Name And Address of Applicant-	K 7 International High School TP-8, FP-1, Nr. BRTS BUS Charging Station, Canal Road, Palanpur gam, Surat.			Report No.	No.Q-1/PHL/WC/B-1722/2023-24
				Receipt No.	389180
				ULR No.	-
				Date of Sample	15/02/2024
Type of Sample:-	Private	Register Entry No.	1722	Start Date of Analysis	17/02/2024
Source of the Water:-	Drinking Water			End Date of Analysis	17/02/2024

Test Report

Sample Description :- A plastic bottle

Physical Appearance: - Clear Liquid

Loose

Sr. No.	Quality Characteristic Test	Name of Method of test used	Unit	Result	Prescribed std. as per Regulations No. 2.10.9 & as per provision of the Act, Rules & Regulations
1.	Colour	FSSAI Manual of Method-2016 Water Section A Method No.I.1.	Hazen unit	1	Max.5
2.	Taste	FSSAI Manual of Method-2016 Water Section A Method No.I.4.	-	Agreeable	Agreeable
3.	Odour	FSSAI Manual of Method-2016 Water Section A Method No.I.2.	-	Agreeable	Agreeable
4.	pH Value	FSSAI Manual of Method-2016 Water Section A Method No.I.3.	-	7.0	6.5 To 8.5
5.	Ammonia (as Total Ammonia-N)	FSSAI Manual of Method-2016 Water Section A Method No.II.1.	mg/l	Absent	Max. 0.5
6.	Nitrate (as NO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.4.	mg/l	Absent	Max. 45
7.	Chlorides (as Cl)	FSSAI Manual of Method-2016 Water Section A Method No.II.5.	mg/l	25.0	Max. 250
8.	Total Alkalinity (as Calcium Carbonate)	FSSAI Manual of Method-2016 Water Section A Method No. II.9.	mg/l	25.0	Max. 200
9.	Total hardness (as CaCO ₃)	FSSAI Manual of Method-2016 Water Section A Method No.II.8.	mg/l	05.0	Max.200
10.	Total Dissolved Solids	FSSAI Manual of Method-2016 Water Section A Method No.I.6.	mg/l	55.0	Max. 500

Opinion: With respect to the test and observation performed, above sample of Drinking Water conforms to the standards and provisions of Food Safety and Standard Act. 2006 and FSS Rules & Regulations.

.....end of the test report.....

Report issue Date :-22/02/2024



[Signature]
Food Analyst
Public Health Laboratory
Surat Municipal Corporation
Surat

Note:- Sampling is not carried out by our authority therefore, the result contained on this report relate only to the sample material tested. Sample drawn by party. Report is meant for guidance only. It is not valid for any litigation or Publicity purpose.

[Signature]
Principal-I/C

K7 International High School, Surat.

K7 International High School

[Signature]

Trustee